



	Code	Bezeichnung	Stk.
1	30096	Boden $\phi$ 650 - unten - CH 500	1
2	42941	Mantel CH 500	1
3	30097	Boden $\phi$ 650 - oben - CH 500	1
4	14258	Muffe 6/4"x20	1
5	19282	Muffe 2"x22	2
6	19277	Muffe 1"x17	1
7	19279	Muffe 1/2"x13	3
8	19280	Muffe 5/4"x13	1
9	30090	Fuss CH 500	3

WINDKESSEL		57.1 kg	1.4301
		Gewicht	Material
Gezeichnet	Datum	Betriebsdruck	6 bar
Cserjes	20.06.2018	Prüfdruck	9,7 bar
1258996	VAR 1	Betriebstemperatur	0 °C - +40 °C
M 1:20	GC CH 500		